



RE: Beaver Brook Mill

From Russell Tedford <rtedford@dracutma.gov>

Date Wed 9/24/2025 1:26 PM

To Alison Manugian <amanugian@dracutma.gov>

📎 2 attachments (5 MB)

Mill St and Lakeview Ave Ramp.png; Lakeview Ave Proposed Crosswalk.png;

Alison,

I have reviewed the plans and only have one comment.

Applicant should remove and replace the handicap ramps at the proposed crosswalk striping on Lakeview Ave and at the northeastern corner of the property for Mill Street/Lakeview Ave intersection. See photos of referenced areas attached

Thanks,
Russ

Russell Tedford, P.E. | Town Engineer



Town Hall | Engineering Department
62 Arlington St. | Dracut, MA 01826
(978) 454-2594
<https://www.dracutma.gov/engineering>